

**BEFORE THE
NEW JERSEY BOARD OF PUBLIC UTILITIES**

**IN THE MATTER OF THE PETITION OF
JERSEY CENTRAL POWER & LIGHT COMPANY PURSUANT TO
N.J.S.A. 40:55D-19 FOR A DETERMINATION THAT THE
OCEANVIEW 230 KV TRANSMISSION PROJECT IS
REASONABLY NECESSARY FOR THE SERVICE, CONVENIENCE
OR WELFARE OF THE PUBLIC**

Direct Testimony

of

Dave Kozy, Jr.

**Re: The Design, Engineering, Construction, Operation and
Maintenance of the Project**

1 **I. INTRODUCTION AND BACKGROUND**

2 **Q. Please state your name and business address.**

3 A. My name is Dave Kozy, Jr. My business address is 76 South Main Street, Akron,
4 Ohio 44308.

5 **Q. By whom are you employed and in what capacity?**

6 A. I am employed by FirstEnergy Service Company (“FirstEnergy”), as General
7 Manager of Transmission Engineering. I am responsible for the management of
8 engineering and design activities with regard to the construction, operation, and
9 maintenance of FirstEnergy’s transmission lines. My role includes the
10 management of transmission line work associated with Jersey Central Power &
11 Light Company’s (“JCP&L”) “Energizing the Future” transmission projects, such
12 as the Oceanview 230 kilovolt (“kV”) Transmission Project (the “Project”).

13 **Q. Please describe your professional experience and educational background.**

14 A. I began my career as a Substation Engineer with Ohio Edison Company, a
15 predecessor to FirstEnergy, in June, 1987. I was promoted to Construction
16 Engineer in August, 1989 and was then promoted to Transmission Engineer in
17 February, 1991. I have been in the Transmission Engineering Department since
18 1991. I have held different positions (Transmission Engineer, Advanced
19 Engineer, Senior Engineer, Supervisor, and Manager) prior to being promoted to
20 General Manager, Transmission Engineering in April, 2011. All employment has
21 been with FirstEnergy or its predecessors.

22 My education, experience and qualifications are fully-set forth in
23 Appendix A to my testimony.

1 **Q. Have you previously testified in Board of Public Utilities (“Board” or**
2 **“BPU”) proceedings?**

3 A. No.

4 **Q. Have you testified before any government body relating to transmission**
5 **projects?**

6 A. Yes. I have testified before the Pennsylvania Public Utility Commission. I have
7 also testified before the Ohio Power Siting Board. In Pennsylvania, I provided
8 testimony on the Bedford North – Osterburg East 115 kV Transmission Line
9 Project Docket Number A-2011-2247862. Before the Ohio Power Siting Board I
10 have provided testimony on the Geauga County 138 kV Transmission Line Supply
11 Project, Docket Number 07-0171-EL-BTX.

12 **II. PROJECT OVERVIEW**

13 **Q. Would you describe the purpose of your testimony?**

14 A. The purpose of my testimony is to describe JCP&L’s plans for designing,
15 engineering, and constructing the Project. I will also explain the plans for
16 operating and maintaining the Project, including the removal and control of
17 vegetation and trees along the right-of-way (“ROW”)

18 **Q. Are you sponsoring any Exhibits?**

19 A. Yes, I am sponsoring the following exhibits:

20 Exhibit DRK-1: Preliminary engineering corridor cross section of the existing
21 corridor from the Larrabee substation to Herbertsville Road;

22
23 Exhibit DRK-2: Preliminary engineering corridor cross section of the existing
24 corridor from Herbertsville Road to the Atlantic substation;

25

- 1 Exhibit DRK-3: Preliminary engineering renderings of the proposed ROW
2 corridor, showing the davit arms and suspension type insulator configuration
3 between Larrabee substation and Herbertsville Road;
4
5 Exhibit DRK-4: Preliminary engineering renderings of the proposed ROW
6 corridor, showing the horizontal braced post insulator configuration between
7 Larrabee substation and Herbertsville Road;
8
9 Exhibit DRK-5: Preliminary engineering renderings of the proposed ROW
10 corridor, showing the davit arms and suspension type insulator configuration
11 between Herbertsville Road and the Atlantic substation;
12
13 Exhibit DRK-6: Preliminary engineering renderings of the proposed ROW
14 corridor, showing the horizontal braced post insulator configuration between
15 Herbertsville Road and the Atlantic substation;
16
17 Exhibit DRK-7: Preliminary engineering corridor cross section of the existing
18 corridor from the Atlantic substation to Oceanview substation;
19
20 Exhibit DRK-8: Preliminary engineering renderings of the proposed ROW
21 corridor configuration between the Atlantic substation to the Oceanview
22 substation;
23
24 Exhibit DRK-9: Photo of typical existing structures from the Atlantic
25 substation to the Oceanview substation;
26
27 Exhibit DRK-10A – 10B: Project Overview Map; and
28
29 Exhibit DRK-11A – 11AD: Preliminary Project Construction Access Maps.
30
31

32 **Q. Please describe the Project from an engineering perspective.**

- 33 A. During the Regional Transmission Expansion Planning (“RTEP”) process, PJM
34 Interconnection L.L.C. (“PJM”) identified the need to construct a new 230 kV
35 transmission line that would feed the Oceanview substation. From an engineering
36 and design perspective, the Project is divided into three major segments. The first
37 two segments are between Larrabee substation in Howell Township heading north
38 towards Atlantic substation in Colts Neck Township. Segment 1 is the ROW
39 portion south of Herbertsville Road in Howell Township, and Segment 2 is the

1 ROW portion north of Herbertsville Road. Both of these ROW segments are
2 approximately 200 to 210 feet wide and the only difference is the location of the
3 existing double circuit steel lattice tower. In Segment 1, the centerline of existing
4 tower is located approximately 60 feet off the western edge of the ROW. *See*
5 Exhibit DRK-1. In Segment 2, the existing steel lattice tower switches to the other
6 side, approximately 60 feet off the eastern edge of the ROW. *See* Exhibit DRK-2.
7 Segment 3 of the Project is the 100 foot wide ROW between Atlantic substation in
8 Colts Neck to the Oceanview substation in Neptune Township. *See* Exhibit DRK-
9 7.

10 In Segments 1 and 2, new single-circuit steel monopoles will be added to
11 the open side of the ROW to support the new 230 kV circuit. In Segment 1 the
12 new monopoles will be placed approximately 75 feet off the eastern side of the
13 ROW, as shown in Exhibits DRK-3 and DRK-4. In Segment 2, the new
14 monopoles will be placed approximately 75 feet off the eastern side of the ROW,
15 as shown in Exhibits DRK-5 and DRK-6. In Segment 3, the existing double-
16 circuit wood structures will be removed and two rows of new steel monopoles
17 will be installed. The pole line on the north side of the ROW will carry the two
18 existing 230 kV circuits and the pole line on the south side of the ROW will carry
19 the new 230 kV circuit, as shown in Exhibit DRK-8.

20 In Segments 1 and 2, the single circuit structures will have one set of three
21 phases arranged vertically on alternating sides of the structure. In Segment 3, the
22 single-circuit structure will have three phases arranged vertically on one side of

1 the structure. The double-circuit structures will have two sets of three phases
2 arranged vertically on either side of the structure.

3 Each phase of the existing and new 230 kV circuits phase will have a
4 single 1.5-inch diameter conductor (1590 kcmil 45/7 Aluminum Conductor Steel
5 Reinforced, called “Lapwing”). There are also two grounded lightning shield
6 wires placed above the top phase conductor attachment points (7#8 Alumoweld).
7 Minimum midspan conductor-to-ground clearance for each new 230 kV circuit
8 will be greater than 26 feet at maximum conductor temperature. The ROW widths
9 for the Project are approximately 200 feet from Larrabee to Atlantic and
10 approximately 100 feet from Atlantic to Oceanview.

11 The Project also will involve reconfiguration of both the Oceanview and
12 Larrabee substations. In order to accommodate the new Larrabee – Oceanview
13 230 kV line, the Oceanview 230 kV substation will be converted to a six breaker
14 ring bus with five breakers initially. The five Oceanview 230 kV ring bus
15 positions will be occupied by two existing Atlantic – Oceanview 230 kV lines,
16 two existing Oceanview 230-34.5 kV transformers, and the one new Larrabee –
17 Oceanview 230 kV line. The Larrabee 230 kV substation will be converted from
18 a ring bus configuration with 8 breakers to a breaker-and-a-half configuration
19 with 11 breakers.

20 **III. DESIGN OF TRANSMISSION STRUCTURES**

21 **A. Segments 1 and 2**

22 **Q. Does JCP&L have an existing transmission line running from the Larrabee**
23 **substation to the Atlantic substation?**

1 A. Yes. JCP&L currently has two 230 kV circuits running from Larrabee substation
2 to Atlantic Substation on double-circuit steel lattice towers, as shown in Exhibits
3 DRK-1 and 2. The two circuits supply energy to the Atlantic substation.

4 **Q. Is JCP&L proposing to replace or upgrade the existing transmission line**
5 **from Larrabee substation to the Atlantic substation?**

6 A. No. JCP&L is only proposing to construct a new 230 kV transmission line from
7 the Larrabee substation to the Atlantic substation area. This new 230 kV
8 transmission line will be located adjacent to the existing transmission lines. The
9 new 230 kV transmission line will not enter Atlantic substation, but will continue
10 from the Atlantic substation area to the existing Oceanview substation.

11 **Q. What is the width of the ROW for Segments 1 and 2?**

12 A. The existing ROW is approximately 200 to 210 feet wide.

13 **Q. What is the height of the existing structures located in Segments 1 and 2?**

14 A. The existing structures range in height from approximately 110 feet to 160 feet
15 tall.

16 **Q. What is the height of the proposed structures for Segments 1 and 2?**

17 A. Based on preliminary engineering design, the proposed structures in Segment 1
18 will range from 90 feet to 130 feet. In Segment 2 the proposed structures will
19 range in height from 80 feet to 160 feet tall.

20 **Q. Can you describe the proposed structure design and type of tower proposed**
21 **for Segments 1 and 2?**

22 A. JCP&L is proposing to install single steel monopoles. Based on the location of the
23 monopoles, the monopoles will have either davit arms and suspension type

1 insulators installed or horizontal braced post insulators that are directly connected
2 to the steel monopole. Please see Exhibits DRK-3 through DRK-6 for
3 engineering drawings of the proposed structures for Segments 1 and 2.

4 **Q. How is the monopole structure constructed?**

5 A. A monopole structure is manufactured and constructed in sections limited by
6 length and weight for shipping and erection purposes. Monopoles require very
7 large construction support equipment on site for erection.

8 **Q. What type of foundations or footings will be used for the monopole
9 structures in Segments 1 and 2?**

10 A. The foundations will be reinforced concrete drilled piers.

11 **B. Segment 3**

12 **Q. Does JCP&L have existing infrastructure running from Atlantic substation to
13 the Oceanview substation?**

14 A. Yes, JCP&L has two 230 kV circuits built on common structures that go from the
15 existing Atlantic substation to the existing Oceanview substation.

16 **Q. When was the existing line constructed from Atlantic substation to the
17 Oceanview substation?**

18 A. Records indicate that the existing 230 kV transmission structures on the ROW
19 from the Atlantic substation to the Oceanview substation were built in 1977.

20 **Q. What is the width of the ROW between the Atlantic substation and the
21 Oceanview substation?**

22 A. The existing ROW width is approximately 100 feet wide for the entire length.

1 **Q. What is the design of the existing structures from the Atlantic substation to**
2 **the Oceanview substation?**

3 A. The existing design is a wooden H-Frame type structure with 3 cross-arms
4 supporting the two circuits on the outside of the structures. A photo of the
5 existing structures on this ROW is located in Exhibits DRK-9.

6 **Q. What is the approximate height of the existing 230 kV structures from the**
7 **Atlantic substation to the Oceanview substation?**

8 A. The existing structures from the Atlantic substation to the Oceanview substation
9 are 80 feet to 100 feet tall.

10 **Q. Please describe the proposed structure for rebuilding the existing 230 kV**
11 **transmission line from the Atlantic substation to the Oceanview substation**
12 **(Segment 3).**

13 A. The existing double-circuit wood structures (as shown in Exhibit DRK-7 and
14 DRK-9) will be removed and replaced with two new steel monopoles. The pole
15 line on the north side of the ROW will carry the two existing 230 kV circuits and
16 the pole line on the south side of the ROW will carry the new 230 kV circuit (as
17 shown in Exhibit DRK8).

18 **Q. What is the height of the structures for the 230 kV transmission lines in**
19 **Segment 3?**

20 A. Based on preliminary engineering design, the proposed structures in Segment 3
21 will range between 80 feet to 115 feet tall.

22 **Q. Can you describe the proposed structure design for the new and existing**
23 **230 kV transmission line in Segment 3?**

1 A. JCP&L is proposing to install single steel monopoles. The monopoles will have
2 horizontal braced post insulators that are directly connected to the steel monopole.
3 Please see Exhibit DRK-8 for preliminary engineering drawings of the proposed
4 structures for Segment 3.

5 **Q. What type of foundations or footings will be used for the monopole**
6 **structures in Segment 3?**

7 A. The foundations will be reinforced concrete drilled piers.

8 **IV. PROJECT DESIGN**

9 **Q. What will the voltage of the new conductors be for this Project?**

10 A. This transmission line will be constructed and operated at 230,000 volts, which is
11 also described as a 230 kV.

12 **Q. What are the size, type and number of conductors planned for this Project?**

13 A. Transmission lines transmit 3-phase electrical power. Each phase requires one or
14 more conductors. A single-circuit transmission line structure must be capable of
15 supporting three phases. A double-circuit structure must be capable of supporting
16 six phases. "Shield wires" are one or two smaller steel or aluminum cables or
17 fiber optic cables that are suspended above the upper conductor. The shield wires
18 are intended to intercept lightning strikes, which would electrically interfere with
19 the power system if they were to strike the conductors directly. The shield wires
20 may also have a fiber optic communications capability for use in controlling the
21 operation of the transmission system.

22 The 230 kV circuits for Segment 1, 2, and 3 will be utilizing a single 1590
23 kcmil 45/7 Aluminum Conductor Steel Reinforced "Lapwing" conductor per

1 phase that is 1.502 inches in diameter, weighs approximately 10,777 pounds per
2 mile and has a rated breaking strength of 43,800 pounds. The 45/7 designation
3 indicates the stranding of the conductor, with the 45 representing the outer 45
4 aluminum wires and the 7 representing the inner 7 steel wires.

5 **Q. Will there be any other overhead wires on the structures in connection with**
6 **this Project?**

7 A. Yes. The static or shield wire will be 7#8 Alumoweld, and will be installed above
8 the top phase conductor attachment points for lightning and relay protection.

9 **Q. Please describe the configuration of the conductors and why this**
10 **configuration was selected.**

11 A. In Segments 1 and 2, JCP&L will be installing a single-circuit 230 kV monopole
12 that will have one set of three phases arranged vertically on alternating sides of
13 the structure using one conductor per phase. In Segment 3, JCP&L will be
14 installing on the south side of the ROW, a single-circuit 230 kV monopole that
15 will have three phase arranged vertically on one side of the structure using one
16 conductor per phase. JCP&L will also be installing on the north side of the ROW,
17 one double-circuit 230 kV monopole structure that will have two sets of three
18 phases arranged vertically on either side of the structure using one conductor per
19 phase.

20 The vertical configuration is typical for these types of project and is also
21 economical. The vertical configuration also allows for a compact design which
22 minimizes: (i) electric and magnetic fields; and (ii) the visual impacts that the
23 monopoles may have on the ROW.

1 **Q. What is the height range of the proposed transmission structures that will be**
2 **constructed for this Project?**

3 A. Based on preliminary engineering design the proposed structures are expected to
4 range in height from approximately 80 feet to approximately 160 feet tall.

5 **Q. What factors determined the height of the monopoles?**

6 A. The factors which determine structure height include: (i) terrain; (ii) National
7 Electric Safety Code clearance requirements; (iii) phase to phase clearance; (iv)
8 phase to ground clearance; (v) phase to other utilities clearance; and (vi) crossing
9 of roads, other structures, and bodies of water.

10 **Q. Does JCP&L plan to use the lowest height monopoles that satisfy**
11 **engineering, safety, and reliability concerns for the Project?**

12 A. Yes. JCP&L uses the most cost-effective structures possible that minimize
13 electric and magnetic fields and visual impacts, while meeting all NESC,
14 Occupational Safety and Health Administration (“OSHA”), and FirstEnergy
15 clearance and safety requirements.

16 **Q. Does JCP&L have transmission structures at a similar height anywhere else**
17 **in New Jersey?**

18 A. Yes. Most JCP&L transmission circuits 230 kV or greater have transmission
19 structures that range in height from 80 feet to 160 feet tall. For example, in the
20 vicinity of the Project area, the Atlantic – South River 230 kV, Atlantic – Red
21 Bank 230 kV, Atlantic –Smithburg 230 kV, Lakewood – Larrabee 230 kV,
22 Larrabee – Smithburg 230 kV all have structures of similar height.

1 **Q. Are there any transmission lines owned by JCP&L that consistently have**
2 **towers exceeding 80 feet in height?**

3 A. Most JCP&L transmission circuits that are 230 kV or greater have a majority of
4 structures that are 80 feet or taller.

5
6 **V. INFRASTRUCTURE BENEFITS AND LOCATION**

7 **Q. What factors does JCP&L consider in its decision regarding structure design**
8 **and location?**

9 A. The design and location of the transmission structures are based on the natural
10 environment. Specifically, the Company will need to manage steep land, avoid
11 wetlands, properly cross bodies of water and roads, and design structures that are
12 able to withstand severe weather conditions. Other factors that influence design
13 and location are proper clearance to ground, FirstEnergy voltage standards, effects
14 on foundation, and property owner impacts.

15 JCP&L, along with its consultants, will carefully review the final location
16 of each of the new structures to minimize the number of structures, and avoid
17 wetlands, steep topography, and difficult access requirements.

18 **Q. Please explain where the transmission structures will be located in the ROW.**

19 A. Please see Exhibits DRK-3 through DRK-6 and DRK-8, which show the proposed
20 centerline within the ROW based on the preliminary engineering. In Segment 1,
21 the new structures will be placed approximately 75 feet from the eastern ROW
22 edge, as shown in Exhibits DRK-3 and DRK-4. In Segment 2, the new structures
23 will be placed approximately 75 feet from the western ROW edge, as shown in
24 Exhibits DRK-5 and DRK-6. In Segment 3, the new structures will be placed

1 approximately 40 feet from the northern ROW edge and approximately 20 feet
2 from the southern ROW edge, as shown in Exhibit DRK-8.

3 **Q. Please describe the temperature at which the conductors will operate.**

4 A. The line will be designed to operate at a maximum design temperature of 212
5 degree Fahrenheit (“F”).

6 **Q. Please describe the minimum conductor to ground clearance under
7 maximum operating conditions the design will meet.**

8 A. The transmission line will be designed to meet or exceed the NESC requirements
9 under all operating conditions. In general, the minimum NESC conductor to
10 ground clearance on public access areas is 22.5 feet, although the minimum
11 requirements vary depending on what the conductor is traveling over. NESC
12 Code clearances are different for bodies of water, railroad crossings and crossing
13 over other types of structures, such as buildings. JCP&L will meet or exceed all
14 NESC requirements.

15 **Q. Did JCP&L consider placing the 230 kV facilities underground?**

16 A. Yes.

17 **Q. In your opinion, would undergrounding these facilities be a reasonable
18 alternative for this Project? Why or why not?**

19 A. No. JCP&L does not believe undergrounding these facilities is a reasonable
20 alternative for this Project for the following reasons:

21 1. Environmental Impacts. Underground cables and the buried concrete duct
22 banks would require extensive excavation that could negatively impact streams,

1 wetlands, and other sensitive areas, especially in the rugged terrain associated
2 with the ROW.

3 2. Restoration Period. When an underground transmission line is
4 experiencing a problem, it will take longer to repair the underground transmission
5 line compared to an overhead transmission line. Due to specialized equipment
6 being needed to determine the location of a fault for an underground transmission
7 line and the excavation that is necessary to reach the fault a repair may take
8 weeks, whereas that same repair for an overhead transmission line may take only
9 hours or days.

10 3. Cost. The total cost of the Project is approximately \$64 million.¹ The cost
11 for siting and constructing the transmission line is \$54 million. If the Company
12 was to construct this line underground, the cost would be approximately 4 – 10
13 times as much as the cost to site and construct the transmission line.

14 4. Less capacity. Underground cables carry far less power than overhead
15 lines of the same size. In order to protect the underground cables, those cables are
16 placed in plastic encasement or oil filled reservoirs. Overhead transmission lines
17 do not require the same type of protection. Therefore, multiple cables will be
18 needed for an underground transmission line to transfer the same capacity as
19 overhead transmission line.

20 **Q. Are there existing gas or oil pipelines in the ROW or adjacent to the ROW**

21 A. No.

22

¹ The \$64 million cost of the Project does not include overhead costs.

1 **VI. ACCESS AND CONSTRUCTION**

2 **Q. As a General Manager of Transmission engineering, are you responsible for**
3 **designing and implementing a construction plan?**

4 A. Yes.

5 **Q. Please describe, in general terms, the construction process.**

6 A. The Project will be constructed according to a well-defined procedure that utilizes
7 standard construction practices to perform all work safely and in compliance with
8 OSHA Rules and Regulations, while keeping environmental impact to a
9 minimum. Project activities will include the installation and maintenance of soil
10 erosion and sedimentation control measures, i.e., silt fencing, temporary access
11 route construction, right-of-way clearing, foundation, structure and wire
12 installations, and the rehabilitation of all areas disturbed during construction, e.g.,
13 reseeded of disturbed areas.

14 **Q. Who will be performing the construction, JCP&L or a contractor?**

15 A. JCP&L is anticipating using contractors for construction. However, JCP&L will
16 at all times remain responsible for the oversight of the construction.

17 **Q. How will JCP&L oversee construction?**

18 A. JCP&L will use a combination of in-house expertise coupled with third party
19 external resources to manage and oversee the construction of the Project. Large
20 projects of these types typically require the use of external resources due to their
21 size, scope and duration. JCP&L normally uses an in-house Project manager to
22 oversee several projects of this size, along with an external project manager for
23 each individual project.

1 **Q. Do you anticipate that construction of the structures for the new 230 kV**
2 **transmission line (Segments 1, 2, and 3) and the removal and replacement of**
3 **the structures for the existing 230 kV line (Segment 3) will be within the**
4 **existing ROW on which JCP&L currently has legal rights?**

5 A. Yes. The Company plans on constructing the Project within existing ROW.
6 However, the Company is reviewing whether it may need to amend certain
7 easements, and may need additional easements for additional tree clearing rights
8 along the edge of the existing ROW as discussed in Tracey J. Janis's Testimony.

9 **Q. Please describe the relationship of the proposed ROW width to design and**
10 **NESC requirements for the Project?**

11 A. The ROW width was determined in order to provide necessary conductor
12 clearances when considering structure type, conductor motion, line voltage, and
13 NESC-defined weather conditions.

14 **Q. How do you anticipate access for construction will be completed?**

15 A. Construction access needs along the route are being identified as part of JCP&L's
16 design effort and the Company plans to use existing ROW access routes. Where
17 there is no current access, JCP&L will need to locate access points and negotiate
18 with property owners for the right to access these properties. The preliminary
19 planned access routes are shown in Exhibit DRK-11A through DRK-11AD.

20 **Q. What will the driving factor in determining the type of access needed?**

21 A. The ability to move equipment to each location in order to construct the 230 kV
22 transmission line.

23 **Q. What material will JCP&L use to construct access roads?**

1 A. Access road material is dependent upon site-specific conditions and requirements.

2 However, typical construction access road materials consist of stone and matting.

3 **Q. Where do you anticipate construction lay down areas will be located?**

4 A. Construction lay down areas not adjacent to or part of the structure lay down area
5 will be determined as part of the detailed design effort. However, JCP&L
6 anticipates that the Larrabee, Atlantic and Oceanview substations, as well as
7 existing ROW, will be used as part of the Company's construction laydown areas.

8 **Q. What factors determine the proposed location of access roads?**

9 A The factors JCP&L considers in determining access road locations are: (i)
10 proximity to structures; (ii) locations; (iii) environmental impacts; (iv)
11 topography; (v) structure type; (vi) adjacent access; and (viii) property rights.

12 **Q. Do you anticipate any clearing of the ROW will be necessary for
13 construction?**

14 A. Yes. The current ROW between Larrabee substation and Atlantic substation will
15 need to be cleared for the new circuit. The ROW for this section has been
16 maintained for the existing circuits within the ROW. As I previously mentioned,
17 the Company may need additional easements for additional tree clearing rights
18 along the edge of the existing ROW.

19 **Q. What steps are planned for minimizing the effects of construction on areas
20 within and outside of the ROW, including such things as traffic and other
21 local community issues?**

22 A. All work will commence and be conducted in accordance with all applicable state
23 and local permits, property releases and approved special conditions. JCP&L

1 will, at all times, minimize to the greatest extent practical the impacts of
2 construction activities on local communities.

3 **Q. What method or methods will be used to clear and otherwise prepare the**
4 **ROW for construction?**

5 A. The construction specifications adopted for the Project are designed to keep
6 environmental impact to a minimum. In addition to the implementation of Best
7 Management Practices (“BMPs”), JCP&L’s efforts during the ROW preparation
8 phase of construction will include the following:

9 1. A copy of the Soil Erosion and Sedimentation Control Plan (“E&S
10 Plan”), along with the appropriate permit forms, will be submitted to the Freehold
11 Soil Conservation District for approval.

12 2. Soil Erosion and Sedimentation Control measures will be installed prior
13 to any earth disturbance.

14 3. Construction access routes will be installed in accordance with the E&S
15 Plan. JCP&L will attempt to avoid installing any permanent access roads. Where
16 access routes were needed for construction, the routes will be re-graded to pre-
17 construction contours and re-vegetated with appropriate vegetation.

18 4. Disturbed work areas will be re-vegetated in accordance with the E&S
19 Plan.

20 5. The initial clearing will be performed in accordance with N.J.A.C 14:5-
21 9.6 and the Company’s Vegetation Management Program. The Company’s
22 Vegetation Management Program includes the removal of all incompatible
23 vegetation within the Transmission clearing zone. The transmission clearing zone

1 corridor refers to the clearing width to be achieved at the time of routine
2 vegetation management. All incompatible vegetation overhanging the
3 transmission clearing zone corridor that is within the minimum clearance
4 requirements shall be removed, pruned to the main stem, or controlled using
5 herbicides.

6 When required, JCP&L's standard specifications will be modified and/or
7 amended to comply with all terms of the applicable permits required to construct
8 the Project.

9 **Q. After construction is completed, will JCP&L take steps to upgrade, seed, or
10 otherwise restore disturbed right-of way and any access roads?**

11 A. Yes. After construction, drainage, fencing and erosion control aspects of the
12 transmission line ROW will be restored to conditions as good as or better than
13 those that existed prior to construction. This includes the restoration of drainage
14 ditches, fencing, field drainage tiles, fertilizing, seeding and mulching of disturbed
15 non-cultivated areas and the removal of temporary soil erosion and sedimentation
16 control measures after vegetative cover has been established. Where required,
17 access roads shall be removed and the area restored to as good or better condition
18 than existed prior to construction

19 **Q. What is the timetable to complete construction and have facilities in service?**

20 A. The construction schedule will be established to meet a June 1,
21 2017 in-service date. JCP&L anticipates access road construction will start in
22 early 2016 and actual transmission line construction is estimated to take 12 to 16
23 months.

1 **Q. What is the estimated cost to site and construct the Project?**

2 A. As I discussed earlier in my testimony, the total Project cost is approximately \$64
3 million², which includes construction work at two existing substations -
4 Oceanview and Larrabee.

5 **Q. Please explain why the estimate to site and construct the Project has changed**
6 **from the \$44.5 million figure identified during the public meetings for the**
7 **Project in Spring 2013 to \$64 million?**

8 A. The \$44.5 million number was a preliminary estimate for siting and construction
9 of the transmission line only. The number did not include the substation portion
10 of the Project. The \$64 million includes the transmission line and substation work
11 associated with the Project. The Company reviews the Project estimates on a
12 regular basis. Based on the Company's review, the Company is seeing higher
13 than anticipated labor and material costs than originally forecasted for the
14 transmission line portion of the Project.

15 **Q. Will property owners be notified when construction begins? How?**

16 A. Yes. The Company's project managers typically notify property owners that are
17 on the ROW or adjacent to the ROW via letter approximately one month prior to
18 start of construction for each area.

19 **Q. Do you have any safety concerns regarding the construction of the Project?**

20 A. No. The Project will be constructed according to a well-defined procedure that
21 utilizes standard construction practices to perform all work safely and in
22 compliance with OSHA Rules and Regulations.

23

² The \$64million Project cost does not include overhead costs.

1 **VII. MAINTENANCE**

2 **Q. Under what general parameters will JCP&L maintain the Project's ROW?**

3 A. Tall-growth vegetation within the line ROW will be removed. Dead, dying and
4 deceased vegetation that is outside of the easement will be removed before it
5 causes a service interruption or interferes with line inspections or repairs. This
6 task – typically referred to as “brush control” - may be accomplished by the use of
7 herbicides, mechanical mowing, or hand cutting. Tree limbs that threaten to
8 intrude into the ROW from trees growing outside the ROW will be removed
9 before they pose a threat or cause damage to the line conductor or other facilities.
10 This “vegetation removal” will be accomplished by a wide variety of mechanical
11 trimmers, manual trimming, or the aerial saw, as conditions require.

12 Entire trees, both within and outside of the ROW, will be removed when
13 they exhibit weakness or structural damage and thereby pose a high degree of risk
14 to the line's uninterrupted service. This tree removal process will apply to any
15 dead or live priority trees, and will be accomplished using any tool at JCP&L's
16 disposal that can safely and quickly remediate the hazard. JCP&L's overarching
17 goal is to prevent all vegetation-caused service interruptions at the lowest possible
18 cost by removing potentially threatening vegetation at the most advantageous
19 time. In order to remove trees that are outside the Company's ROW (i.e., off-
20 corridor), JCP&L will have to obtain the necessary rights from the applicable
21 property owners.

22 **Q. Please describe the expected ROW maintenance cycle for this Project.**

1 A. The Company will comply with both N.J.A.C. 14:5-9.6 and the Company's
2 Transmission Vegetation Management program. The JCP&L service territory is
3 currently on a five-year maintenance schedule for all transmission voltages. Each
4 transmission circuit within the FirstEnergy footprint has a vegetation maintenance
5 plan filed with FERC that FirstEnergy is required to follow. The plan for this
6 Project will be filed after the transmission line is placed in service.

7 **Q. Does this conclude your direct testimony?**

8 A. Yes, it does.

Dave Kozy, Jr.

Education

1987 University of Akron, BS Civil Engineering

Experience

1987 – 1989 Substation Engineer B, Substation Engineering, Ohio Edison Company
1989 – 1991 Construction Engineer A, Substation Construction, Ohio Edison Company
1991 – 1996 Transmission Engineer, Transmission Engineering, Ohio Edison Company
1996 – 2004 Advanced Engineer, Transmission Engineering, FirstEnergy Service Company
2004 – 2006 Senior Engineer, Transmission Engineering, FirstEnergy Service Company
2006 – 2008 Supervisor, Transmission Engineering, FirstEnergy Service Company
2008 – 2011 Manager, Transmission Engineering, FirstEnergy Service Company
2011 – Present General Manager, Transmission Engineering, FirstEnergy Service Company

Professional Engineer

Licensed in Ohio, Pennsylvania, New Jersey, West Virginia, Maryland and Virginia

Provided testimony in the following cases:

Ohio Power Siting Board Case:

Docket No. 07-0171-EL-BTX, Geauga County 138 kV Transmission Line Supply Project

Pa P.U.C. Case:

Docket No. A-2011-2247862, Bedford North – Osterberg East 115 kV HV Transmission Line Project

Exhibit DRK-1

EXISTING
R/W

EXISTING
R/W

200'

EXISTING 230kV
TRANSMISSION TOWER
400'-750' SPANS

EXISTING 34.5kV
WOOD POLE

10.5'
(TYP)

11'
(TYP)

10'
(TYP)

21'
(TYP)

20'-6"
(TYP)



18'
(TYP)

110'-160'

60'

115'

25'



**PRELIMINARY - NOT
FOR CONSTRUCTION**

LARRABEE-OCEANVIEW
(LOOKING NORTH)
LARRABEE SS TO HERBERTSVILLE ROAD
3.5 MILES
TYPICAL EXISTING CORRIDOR



Jersey Central
Power & Light
A FirstEnergy Company
Transmission Design
CORRIDOR CROSS SECTION
LARRABEE-OCEANVIEW 230kV
DRK-EXHIBIT 1


Exhibit DRK-2

EXISTING
R/W

EXISTING
R/W

200'



EXISTING 230kV
TRANSMISSION TOWER
500'-900' SPANS



110'-150'

140'

60'



**PRELIMINARY - NOT
FOR CONSTRUCTION**

LARRABEE-OCEANVIEW
(LOOKING NORTH)
HERBERTSVILLE ROAD TO ATLANTIC SS
8.0 MILES
TYPICAL EXISTING CORRIDOR



Jersey Central
Power & Light
A FirstEnergy Company
Transmission Design
CORRIDOR CROSS SECTION
LARRABEE-OCEANVIEW 230kV
DRK-EXHIBIT 2

Exhibit DRK-3

EXISTING
R/W


EXISTING
R/W

200'

EXISTING 230kV
TRANSMISSION TOWER
400'-750' SPANS

PROPOSED 230 kV
MONOPOLE
400'-750' SPANS

EXISTING 34.5kV
WOOD POLE



**PRELIMINARY - NOT
FOR CONSTRUCTION**

LARRABEE-OCEANVIEW
(LOOKING NORTH)
LARRABEE SS TO HERBERTSVILLE ROAD
3.5 MILES
PROPOSED CORRIDOR
PRELIMINARY ENGINEERING ONLY



Jersey Central
Power & Light

A FirstEnergy Company

Transmission Design
CORRIDOR CROSS SECTION
LARRABEE-OCEANVIEW 230kV
DRK-EXHIBIT 3

Exhibit DRK-4

EXISTING
R/W






EXISTING
R/W

200'

EXISTING 230kV
TRANSMISSION TOWER
400'-750' SPANS

PROPOSED 230 kV
MONOPOLE
400'-700' SPANS

EXISTING 34.5kV
WOOD POLE



60'

65'

50'

25'

110'-160'

APPROX. 90'-120'

21'
(TYP)

18'
(TYP)

10'
(TYP)

20'-6"
(TYP)

10.5'
(TYP)

11'
(TYP)

10'
(TYP)

20'
(TYP)

**PRELIMINARY - NOT
FOR CONSTRUCTION**

LARRABEE-OCEANVIEW
(LOOKING NORTH)
LARRABEE SS TO HERBERTSVILLE ROAD
3.5 MILES
PROPOSED MONOPOLE



Jersey Central
Power & Light
A FirstEnergy Company
Transmission Design
CORRIDOR CROSS SECTION
LARRABEE-OCEANVIEW 230kV
DRK-EXHIBIT 4

Exhibit DRK-5


EXISTING
R/W

EXISTING
R/W

200'

PROPOSED 230 kV
MONOPOLE
500'-900' SPANS

EXISTING 230kV
TRANSMISSION TOWER
500'-900' SPANS



75'

65'

60'

APPROX 80'-130'

110'-150'

8'
(TYP)

15'-2"
(TYP)

16'-3"
(TYP)

20'
(TYP)

15'
(TYP)

10'
(TYP)

10.5'
(TYP)

11'
(TYP)

20'-6"
(TYP)

21'
(TYP)

18'
(TYP)

**PRELIMINARY - NOT
FOR CONSTRUCTION**

LARRABEE-OCEANVIEW
(LOOKING NORTH)
HERBERTSVILLE ROAD TO ATLANTIC SS
8.0 MILES
PROPOSED CORRIDOR
PRELIMINARY ENGINEERING ONLY



Jersey Central
Power & Light
A FirstEnergy Company
Transmission Design
CORRIDOR CROSS SECTION
LARRABEE-OCEANVIEW 230kV
DRK-EXHIBIT 5

COPYRIGHT © 2014, BURNS & MCDONNELL ENGINEERING COMPANY, INC.

Exhibit DRK-6


EXISTING
R/W

EXISTING
R/W

200'

PROPOSED 230 kV
MONOPOLE
500'-700' SPANS

EXISTING 230kV
TRANSMISSION TOWER
500'-900' SPANS



APPROX. 80'-160'

110'-150'

**PRELIMINARY - NOT
FOR CONSTRUCTION**

LARRABEE-OCEANVIEW
(LOOKING NORTH)
HERBERTSVILLE ROAD TO ATLANTIC SS
8.0 MILES
PROPOSED MONOPOLE



Jersey Central
Power & Light
A FirstEnergy Company
Transmission Design
CORRIDOR CROSS SECTION
LARRABEE-OCEANVIEW 230kV
DRK-EXHIBIT 6

Exhibit DRK-7

EXISTING
R/W

EXISTING
R/W

100'

EXISTING 230kV
H-FRAME
250'-700' SPANS

19'
(TYP)

7'



21'
(TYP)

14'
(TYP)

80'-100'

50'

50'



**PRELIMINARY - NOT
FOR CONSTRUCTION**

LARRABEE-OCEANVIEW
(LOOKING EAST)
ATLANTIC SS TO OCEANVIEW SS
5.2 MILES
TYPICAL EXISTING CORRIDOR



Jersey Central
Power & Light


A FirstEnergy Company

Transmission Design
CORRIDOR CROSS SECTION
LARRABEE-OCEANVIEW 230kV
DRK-EXHIBIT 7

Exhibit DRK-8

EXISTING
R/W

EXISTING
R/W



**PRELIMINARY - NOT
FOR CONSTRUCTION**

LARRABEE-OCEANVIEW
(LOOKING EAST)
ATLANTIC SS TO OCEANVIEW SS
5.2 MILES
PROPOSED CORRIDOR
PRELIMINARY ENGINEERING ONLY

	<p>Jersey Central Power & Light <small>A FirstEnergy Company</small></p> <p><i>Transmission Design</i></p> <p>CORRIDOR CROSS SECTION LARRABEE-OCEANVIEW 230kV DRK-EXHIBIT 8</p>
--	--

COPYRIGHT © 2014, BURNS & MCDONNELL ENGINEERING COMPANY, INC.

Exhibit DRK-9




Jersey Central
Power & Light


A FirstEnergy Company

H-FRAME
TRANSMISSION STRUCTURE
LARABEE-OCEANVIEW 230 kV
DRK-EXHIBIT 9

Exhibits DRK-10A-10B



Legend		
	Substation	
	Preferred Route	
	Municipal Boundary	
	County Boundary	
		Existing Transmission



DRK-Exhibit 10A: Project Overview Map

0 0.5 1 1.5 2 2.5 Miles


Data Sources: ESRI, 2012; USGS 2012, NJDEP, 2012
 Geographic Coordinate System: NAD_1983_StatePlane_New_Jersey_FIPS_2900_Feet
 Datum: North American Datum of 1983 (NAD83)
 Projection: Transverse Mercator
 Linear Unit: Foot_US
 Ellipsoid: Geodetic Reference System 80.




Oceanview 230 kV Transmission Line Reinforcement Project

Jersey Central Power & Light
 January 13, 2014

A FirstEnergy Company



Legend		
	Substation	
	Preferred Route	
	Municipal Boundary	
	County Boundary	
		Existing Transmission



DRK-Exhibit 10B: Project Overview Map

0 0.5 1 1.5 2 2.5 Miles

Data Sources: ESRI, 2012; USGS 2012, NJDEP, 2012
 Geographic Coordinate System: NAD_1983_StatePlane_New_Jersey_FIPS_2900_Feet
 Datum: North American Datum of 1983 (NAD83)
 Projection: Transverse Mercator
 Linear Unit: Foot_US
 Ellipsoid: Geodetic Reference System 80.



Oceanview 230 kV Transmission Line Reinforcement Project

Jersey Central Power & Light
January 13, 2014

A FirstEnergy Company

Exhibits DRK-11A-11AD



	Substation		Existing Transmission ROW
	Field Note		Municipal Boundary
	School		County Boundary
	Pull Site/Lay Down Area		Department of Defense
	Access Road		State Parks/State Conservation
	Access Road Option		Local/Private Conservation
	Preferred Route		Parcel boundaries displayed in white
	Preferred Route (Rebuild)		


Tile 1 of 30



DRK-Exhibit 11A
Preliminary Access Roads

0 100 200 300 400 500 Feet

Data Sources: ESRI, 2012; USGS 2012, NJDEP, 2012
Geographic Coordinate System: NAD_1983_StatePlane_New_Jersey_FIPS_2900_Feet
Datum: North American Datum of 1983 (NAD83)
Projection: Transverse Mercator
Linear Unit: Foot_US
Ellipsoid: Geodetic Reference System 80.



Oceanview 230 kV Transmission Line Reinforcement Project

Jersey Central Power & Light
January 15, 2014

Jersey Central Power & Light
A FirstEnergy Company



	Substation		Existing Transmission ROW
	Field Note		230 kV
	School		115/138 kV
	Pull Site/Lay Down Area		< 115 kV
	Access Road		Distribution Line
	Access Road Option		Existing Tower
	Preferred Route		Municipal Boundary
	Preferred Route (Rebuild)		County Boundary
			Department of Defense
			State Parks/State Conservation
			Local/Private Conservation
			Parcel boundaries displayed in white


Tile 2 of 30



DRK-Exhibit 11B
Preliminary Access Roads

0 100 200 300 400 500 Feet

Data Sources: ESRI, 2012; USGS 2012, NJDEP, 2012
Geographic Coordinate System: NAD_1983_StatePlane_New_Jersey_FIPS_2900_Feet
Datum: North American Datum of 1983 (NAD83)
Projection: Transverse Mercator
Linear Unit: Foot_US
Ellipsoid: Geodetic Reference System 80.



Oceanview 230 kV Transmission Line Reinforcement Project

Jersey Central Power & Light
January 15, 2014

Jersey Central Power & Light
A FirstEnergy Company



	Substation		Existing Transmission ROW
	Field Note		Municipal Boundary
	School		County Boundary
	Pull Site/Lay Down Area		Department of Defense
	Access Road		State Parks/State Conservation
	Access Road Option		Local/Private Conservation
	Preferred Route		Parcel boundaries displayed in white
	Preferred Route (Rebuild)		
	Existing Transmission 230 kV		
	Existing Transmission 115/138 kV		
	Existing Transmission < 115 kV		
	Distribution Line		
	Existing Tower		


Tile 3 of 30



DRK-Exhibit 11C
Preliminary Access Roads

0 100 200 300 400 500 Feet


Data Sources: ESRI, 2012; USGS 2012, NJDEP, 2012
 Geographic Coordinate System: NAD_1983_StatePlane_New_Jersey_FIPS_2900_Feet
 Datum: North American Datum of 1983 (NAD83)
 Projection: Transverse Mercator
 Linear Unit: Foot_US
 Ellipsoid: Geodetic Reference System 80.



Oceanview 230 kV Transmission Line Reinforcement Project

Jersey Central Power & Light
 January 15, 2014

Jersey Central Power & Light
 A FirstEnergy Company



	Substation		Existing Transmission ROW
	Field Note		Municipal Boundary
	School		County Boundary
	Pull Site/Lay Down Area		Department of Defense
	Access Road		State Parks/State Conservation
	Access Road Option		Local/Private Conservation
	Preferred Route	Parcel boundaries displayed in white	
	Preferred Route (Rebuild)		
	Existing Transmission 230 kV		
	Existing Transmission 115/138 kV		
	Existing Transmission < 115 kV		
	Distribution Line		
	Existing Tower		


Tile 4 of 30



DRK-Exhibit 11D
Preliminary Access Roads

0 100 200 300 400 500 Feet

Data Sources: ESRI, 2012; USGS 2012, NJDEP, 2012
 Geographic Coordinate System: NAD_1983_StatePlane_New_Jersey_FIPS_2900_Feet
 Datum: North American Datum of 1983 (NAD83)
 Projection: Transverse Mercator
 Linear Unit: Foot_US
 Ellipsoid: Geodetic Reference System 80.



Oceanview 230 kV Transmission Line Reinforcement Project

Jersey Central Power & Light
 January 15, 2014

Jersey Central Power & Light
 A FirstEnergy Company



	Substation		Existing Transmission		Existing Transmission ROW
	Field Note		230 kV		Municipal Boundary
	School		115/138 kV		County Boundary
	Pull Site/Lay Down Area	< 115 kV line symbol"/>	< 115 kV		Department of Defense
	Access Road		Distribution Line		State Parks/State Conservation
	Access Road Option		Existing Tower		Local/Private Conservation
	Preferred Route				Parcel boundaries displayed in white
	Preferred Route (Rebuild)				


Tile 5 of 30



DRK-Exhibit 11E
Preliminary Access Roads

0 100 200 300 400 500 Feet

Data Sources: ESRI, 2012; USGS 2012, NJDEP, 2012
 Geographic Coordinate System: NAD_1983_StatePlane_New_Jersey_FIPS_2900_Feet
 Datum: North American Datum of 1983 (NAD83)
 Projection: Transverse Mercator
 Linear Unit: Foot_US
 Ellipsoid: Geodetic Reference System 80.



Oceanview 230 kV Transmission Line Reinforcement Project

Jersey Central Power & Light
 January 15, 2014

Jersey Central Power & Light
 A FirstEnergy Company



	Substation		Existing Transmission ROW
	Field Note		230 kV
	School		115/138 kV
	Pull Site/Lay Down Area		< 115 kV
	Access Road		Distribution Line
	Access Road Option		Existing Tower
	Preferred Route		Municipal Boundary
	Preferred Route (Rebuild)		County Boundary
			Department of Defense
			State Parks/State Conservation
			Local/Private Conservation
			Parcel boundaries displayed in white


Tile 6 of 30



DRK-Exhibit 11F
Preliminary Access Roads

0 100 200 300 400 500 Feet

Data Sources: ESRI, 2012; USGS 2012, NJDEP, 2012
Geographic Coordinate System: NAD_1983_StatePlane_New_Jersey_FIPS_2900_Feet
Datum: North American Datum of 1983 (NAD83)
Projection: Transverse Mercator
Linear Unit: Foot_US
Ellipsoid: Geodetic Reference System 80.



Oceanview 230 kV Transmission Line Reinforcement Project

Jersey Central Power & Light
January 15, 2014

Jersey Central Power & Light
A FirstEnergy Company



	Substation		Existing Transmission ROW
	Field Note		230 kV
	School		115/138 kV
	Pull Site/Lay Down Area		< 115 kV
	Access Road		Distribution Line
	Access Road Option		Existing Tower
	Preferred Route		Parcel boundaries displayed in white
	Preferred Route (Rebuild)		Municipal Boundary
			County Boundary
			Department of Defense
			State Parks/State Conservation
			Local/Private Conservation


Tile 7 of 30



DRK-Exhibit 11G
Preliminary Access Roads

0 100 200 300 400 500 Feet

Data Sources: ESRI, 2012; USGS 2012, NJDEP, 2012
 Geographic Coordinate System: NAD_1983_StatePlane_New_Jersey_FIPS_2900_Feet
 Datum: North American Datum of 1983 (NAD83)
 Projection: Transverse Mercator
 Linear Unit: Foot_US
 Ellipsoid: Geodetic Reference System 80.



Oceanview 230 kV Transmission Line Reinforcement Project

Jersey Central Power & Light
 January 15, 2014

Jersey Central Power & Light
 A FirstEnergy Company



Substation	Existing Transmission 230 kV	Existing Transmission ROW
Field Note	Existing Transmission 115/138 kV	Municipal Boundary
School	Existing Transmission < 115 kV	County Boundary
Pull Site/Lay Down Area	Distribution Line	Department of Defense
Access Road	Existing Tower	State Parks/State Conservation
Access Road Option		Local/Private Conservation
Preferred Route		Parcel boundaries displayed in white
Preferred Route (Rebuild)		


Tile 8 of 30



DRK-Exhibit 11H
Preliminary Access Roads

0 100 200 300 400 500 Feet


Data Sources: ESRI, 2012; USGS 2012, NJDEP, 2012
 Geographic Coordinate System: NAD_1983_StatePlane_New_Jersey_FIPS_2900_Feet
 Datum: North American Datum of 1983 (NAD83)
 Projection: Transverse Mercator
 Linear Unit: Foot_US
 Ellipsoid: Geodetic Reference System 80.



Oceanview 230 kV Transmission Line Reinforcement Project

Jersey Central Power & Light
 January 15, 2014

Jersey Central Power & Light
 A FirstEnergy Company



Substation	Existing Transmission 230 kV	Existing Transmission ROW
Field Note	Existing Transmission 115/138 kV	Municipal Boundary
School	Existing Transmission < 115 kV	County Boundary
Pull Site/Lay Down Area	Distribution Line	Department of Defense
Access Road	Existing Tower	State Parks/State Conservation
Access Road Option		Local/Private Conservation
Preferred Route		Parcel boundaries displayed in white
Preferred Route (Rebuild)		


Tile 9 of 30



DRK-Exhibit 111
Preliminary Access Roads

0 100 200 300 400 500 Feet

Data Sources: ESRI, 2012; USGS 2012, NJDEP, 2012
 Geographic Coordinate System: NAD_1983_StatePlane_New_Jersey_FIPS_2900_Feet
 Datum: North American Datum of 1983 (NAD83)
 Projection: Transverse Mercator
 Linear Unit: Foot_US
 Ellipsoid: Geodetic Reference System 80.



Oceanview 230 kV Transmission Line Reinforcement Project

Jersey Central Power & Light
 January 15, 2014

Jersey Central Power & Light
 A FirstEnergy Company



- | | | |
|-----------------------------|-----------------------|--------------------------------------|
| ▲ Substation | Existing Transmission | Existing Transmission ROW |
| ◆ Field Note | ● 230 kV | ▭ Municipal Boundary |
| 🏫 School | ● 115/138 kV | ▭ County Boundary |
| ▭ Pull Site/Lay Down Area | ● < 115 kV | ▭ Department of Defense |
| ⋯ Access Road | --- Distribution Line | ▭ State Parks/State Conservation |
| ⋯ Access Road Option | ● Existing Tower | ▭ Local/Private Conservation |
| ▬ Preferred Route | | Parcel boundaries displayed in white |
| ▬ Preferred Route (Rebuild) | | |

Tile 10 of 30

DRK-Exhibit 11J
Preliminary Access Roads

Data Sources: ESRI, 2012; USGS 2012, NJDEP, 2012
 Geographic Coordinate System: NAD_1983_StatePlane_New_Jersey_FIPS_2900_Feet
 Datum: North American Datum of 1983 (NAD83)
 Projection: Transverse Mercator
 Linear Unit: Foot_US
 Ellipsoid: Geodetic Reference System 80.



Oceanview 230 kV Transmission Line Reinforcement Project
 Jersey Central Power & Light
 January 15, 2014